

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF REID VILLAGE WATER )	
DISTRICT FOR A DEVIATION FROM THE )	
REQUIREMENTS OF 807 KAR 5:066, SECTION )	CASE NO. 90-186
5(4), REGARDING WATER STORAGE )	

O R D E R

By application received June 29, 1990, Reid Village Water District ("Reid Village Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Reid Village Water states in its application that its average daily water usage, including unaccounted-for water, is approximately 106,701 gallons, and that its current water storage capacity is 100,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Reid Village Water is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Reid Village Water should be given until August 1, 1993 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:

1. Reid Village Water be and it hereby is given until August 1, 1993 to comply with the provisions of 807 KAR 5:066, Section 5(4).


2. Reid Village Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to August 1, 1993.

Done at Frankfort, Kentucky, this 20th day of July, 1990.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director